

# PFXGP4503TAD

http://www.axcontrol.com/automation/pro-face/gp-4000/PFXGP4503TAD

# **Pro-face Xycom GP4000**

# PFXGP4503TAD

Pro-face Xycom GP-450xT GP450xT Touch Screen Operator Interface 10.4 TFT Analog Color LCD Display 24VDC UL/CE. Call Now!

1-800-991-7026


sales@axcontrol.com

## See Also:

http://www.axcontrol.com/automation/pro-face/gp-4000

## **Panel Cut Dimensions**


Create a panel cut and insert the GP unit into the opening from the front.



	Α	В	С	R
GP-4501T GP-4503T	259 mm (+1, -0 mm) (10.2 in. [+0.04, -0 in.])	201 mm (+1, -0 mm) (7.91 in. [+0.04, -0 in.])	1.65 mm (0.060.2 in.)	3 mm (0.12 in.) maximum
GP-4501TW	301.5 mm (+1, -0 mm) (11.87 in. [+0.04, -0 in.])	227.5 mm (+1, -0 mm) (8.96 in. [+0.04, -0 in.])		

NOTE: Before designing the panel cut, refer to Installation (see page 136).

## **Installation Fastener Dimensions**



# 4.5 **GP-4600 Series**

## What Is in This Section?

This section contains the following topics:

Торіс	Page
Electrical Specifications	118
Environmental Specifications	119
Structural Specifications	120
Display Specifications	122
Memory, Clock, and Touch Panel	123
Interface Specifications	124
Specifications of Serial Interface COM1	125
Specifications of Serial Interface COM2	127
Dimensions	129

# **Electrical Specifications**

			DC Model	AC Model
	Rated Input Voltage		24 Vdc	100240 Vac
	Input Vo	oltage Limits	19.228.8 Vdc	85264 Vac
	Rated F	requency	-	50/60 Hz
	Rated F	requency Range	-	4763 Hz
Voltage Drop ≥		Drop	10 ms or less	1 cycle or less (Voltage drop interval must be 1 second or more)
er Supply	Power 0	Consumption	17 W or less	100 Vac: 44 VA or less 240 Vac: 58 VA or less
Power		When power is not supplied to external devices	12 W or less	100 Vac: 30 VA or less 240 Vac: 44 VA or less
		Backlight OFF (Standby Mode)	7 W or less	100 Vac: 18 VA or less 240 Vac: 29 VA or less
		Backlight Dimmed (Brightness: 20%)	8 W or less	100 Vac: 22 VA or less 240 Vac: 31 VA or less
	In-Rush Current		30 A or less	
Voltage Endurance		durance	1,000 Vac, 20 mA for 1 minute (between charging and FG terminals)	1,500 Vac, 20 mA for 1 minute (between charging and FG terminals)
Insulation Resistance		Resistance	500 Vdc, 10 M $\Omega$ or more FG terminals)	(between charging and

# **Environmental Specifications**

		DC Model	AC Model
Surrounding Air Temperature		055 °C (32131 °F)	
ent	Storage Temperature	-2060 °C (-4140 °F)	
Physical Environment	Surrounding Air and Storage Humidity	1090% RH (Non condensing, wet bulb temperature 39 °C [102.2 °F] or less)	
E	Dust	0.1 mg/m <sup>3</sup> (10 <sup>-7</sup> oz/ft <sup>3</sup> ) or les	s (non-conductive levels)
/sica	Pollution Degree	For use in Pollution Degree 2	2 environment
Ph	Corrosive Gases	Free of corrosive gases	
	Atmospheric Pressure (Operating Altitude)	8001,114 hPa (2,000 m [6,561 ft] or lower)	
Environment	Vibration Resistance	IEC/EN 61131-2 compliant 59 Hz Single amplitude 3.5 mm (0.14 in.) 9150 Hz Fixed acceleration: 9.8 m/s <sup>2</sup> X, Y, Z directions for 10 cycles (approx.100 minute)	
Mechanical Environment	Concussion Resistance	ce IEC/EN 61131-2 compliant 147 m/s <sup>2</sup> , X, Y, Z directions for 3 times	
ronment	Noise Immunity	Noise Voltage: 1,000 Vp-p Pulse Width: 1 μs Rise Time: 1 ns	Noise Voltage: 1,500 Vp-p Pulse Width: 1 μs Rise Time: 1 ns
Electrical Environment	Electrostatic Discharge Immunity	Contact Discharge Method: 6 kV (IEC/EN 61000-4-2 Level 3)	

## Air quality requirements

Do not operate or store the GP unit where chemicals evaporate, or where chemicals are present in the air:

- Corrosive chemicals: Acids, alkalines, liquids containing salt.
- Flammable chemicals: Organic solvents.

# **A** CAUTION

### **INOPERATIVE EQUIPMENT**

Do not allow water, liquids, metal, and wiring fragments to enter the panel case.

Failure to follow these instructions can result in injury or equipment damage.

## Structural Specifications

#### NOTE:

 If you are using the rear mount model, refer to Structural Specifications (see page 182).

Grounding	Functional grounding: Grounding resistance of 100 $\Omega$ , 2 mm <sup>2</sup> (AWG 14) or thicker wire, or your country's applicable standard. (Same for FG and SG terminals)
Cooling Method	Natural air circulation
Structure <sup>*1</sup>	IP65F NEMA #250 TYPE 4X/13 (on the front panel when properly installed in an enclosure)
External Dimensions	W315 x H241 x D56 mm (W12.4 x H9.49 x D2.2 in.)
Panel Cut Dimensions	W301.5 x H227.5 mm (W11.87 x H8.96 in.)* <sup>2</sup> Panel thickness area: 1.65 mm (0.060.2 in.)* <sup>3</sup>
Weight	2.5 kg (5.5 lb) or less (main unit only)

**NOTE:** \*1 The front face of the GP unit, installed in a solid panel, has been tested using conditions equivalent to the standards shown in the specification. Even though the GP unit's level of resistance is equivalent to these standards, oils that should have no effect on the GP unit can possibly harm the panel. This can occur in areas where either vaporized oils are present, or where low viscosity cutting oils are allowed to adhere to the GP unit for long periods of time. If the GP unit's front face protection sheet peels off, these conditions can lead to the ingress of oil into the GP unit and separate protection measures are suggested.

Also, if non-approved oils are present, they may cause deformation or corrosion of the front GP unit's plastic cover. Therefore, prior to installing the GP unit, be sure to confirm the type of conditions that will be present in the GP unit's operating environment. If the installation gasket is used for a long period of time, or if the GP unit and its gasket are removed from the panel, the original level of protection cannot be kept. To maintain the original protection level, be sure to replace the installation gasket regularly.

# **A** CAUTION

#### **EQUIPMENT DAMAGE**

Ensure that the panel is not in permanent and direct contact with oils.

Failure to follow these instructions can result in injury or equipment damage.

 $<sup>^{*2}</sup>$  For dimensional tolerance, everything +1/-0 mm (+0.04/-0 in.) and R in angle are below R3 (R0.12in.)

<sup>\*3</sup> Even if the installation wall thickness is within the recommended range for the "Panel Cut Dimensions", depending on wall's material, size, and installation location of the GP unit and other devices, the installation wall could warp. To prevent warping, the installation surface may need to be strengthened.

# NOTICE

## STORAGE AND OPERATION OUTSIDE OF SPECIFICATIONS

- Store the panel in areas where temperatures are within the panel's specifications.
- Do not restrict or block the panel's rear-face ventilation slots.

Failure to follow these instructions can result in equipment damage.

# NOTICE

### **GASKET AGING**

- Inspect the gasket periodically as required by your operating environment to keep the initial IP level.
- Change the gasket at least once a year, or as soon as scratches or dirt become visible.

Failure to follow these instructions can result in equipment damage.

# **Display Specifications**

Display Type		TFT Color LCD
Display Size		12.1"
Resolution		800 x 600 pixels (SVGA)
Effective Display	Area	W246.0 x H184.5 mm (W9.69 x H7.26 in.)
Display Colors		65,536 colors (No blink) / 16,384 colors (Blink)
Backlight		White LED (Not user replaceable. When replacement is required, contact your local distributor.)
Backlight Service Life		50,000 hours (continuous operation at at 25 °C [77 °F] before backlight brightness decreases to 50%)
Brightness Control		16 levels (Adjusted with touch panel or software)
Language Fonts <sup>*1</sup>		Japanese, ASCII, Chinese (Simplified), Chinese (Traditional), Korean, Cyrillic, Thai
Character Sizes		Standard font: 8 x 8, 8 x 16, 16 x 16 and 32 x 32 pixel fonts Stroke font: 6127 pixel fonts Image font: 872 pixel fonts
Font Sizes		Standard font: You can expand width up to 8 times, and expand height up to 8 times.*2
Text	8 x 8 pixels	100 characters per row x 75 rows
	8 x 16 pixels	100 characters per row x 37 rows
	16 x 16 pixels	50 characters per row x 37 rows
	32 x 32 pixels	25 characters per row x 18 rows

<sup>\*1</sup> Please refer to the GP-Pro EX Reference Manual for details on font types and character codes.

<sup>\*2</sup> You can set up other font sizes using the software.

# Memory, Clock, and Touch Panel

## Memory

Application Memory*1	FLASH EPROM 32 MB (including logic program area)
Logic Program Area	FLASH EPROM 132 KB (Equivalent to 15,000 steps) <sup>*2)</sup>
Font Area	FLASH EPROM 8 MB (when limit exceeded, uses application memory)
Data Backup	SRAM 320 KB (Replaceable lithium battery for backup memory)
Variable Area	SRAM 64 KB (Replaceable lithium battery for retentive variables)

<sup>\*1</sup> Capacity available for user application (internal memory).

#### Clock

 $\pm$  65 seconds per month (deviation at room temperature and power is OFF). Variations in operating conditions and battery life can cause clock deviations from - 380 to +90 seconds per month.

For systems where this level of precision is insufficient, the user should monitor and make adjustments when required.

#### **Touch Panel**

	GP-4601T (Analog Touch Panel) / GP-4603T	GP-4601T (Matrix Touch Panel)
Touch Panel Type	Resistive Film (analog)	Resistive Film (matrix)
Touch Panel Resolution	1,024 x 1,024	40 x 30 keys/screen
Touch Panel Service Life	1 million times or more	

 $<sup>^{^{\</sup>star}2}$  Up to 60,000 steps can be converted in software. However, this reduces application memory capacity for screen data by 1 MB.

# **Interface Specifications**

## **Serial Interface COM1**

Asynchronous Transmission	RS-232C
Data Length	7 or 8 bits
Stop Bit	1 or 2 bits
Parity	None, odd or even
Data Transmission Speed	2,400115,200 bps
Connector	D-Sub 9 pin (plug)

### **Serial Interface COM2**

	GP-4601T	GP-4603T
Asynchronous Transmission	RS-422 / RS-485	RS-485 (isolation)
Data Length	7 or 8 bits	
Stop Bit	1 or 2 bits	
Parity	None, odd or even	
Data Transmission Speed	2,400115,200 bps, 187,500 bps (MPI)	
Connector	D-Sub 9 pin (plug) D-Sub 9 pin (socket)	

### **USB** Interface

	USB (Type A) Interface	USB (mini-B) Interface
Connector	USB 2.0 (Type A) x 1	USB 2.0 (mini-B) x 1
Power Supply Voltage	5 Vdc ±5%	-
Maximum Current Supplied	500 mA	-
Maximum Transmission Distance	5 m (16.4 ft)	

## **Ethernet Interface**

Ethernet (LAN)	IEEE802.3i / IEEE802.3u, 10BASE-T/100BASE-TX
Connector	Modular jack (RJ45) x 1

## **SD Card Interface**

SD Card slot x 1 (maximum 32 GB SD/SDHC Card)

## **Specifications of Serial Interface COM1**

#### Introduction

**NOTE:** For instructions on how to connect to other devices, always refer to the "GP-Pro EX Device/PLC Connection Manual".

The serial port is not isolated. The SG (signal ground) and FG (frame ground) terminals are connected inside the GP unit.

# **A** A DANGER

#### **ELECTRIC SHOCK**

When using the SG terminal to connect an external device to the panel:

- Verify that a short-circuit loop is not created when you set up the system.
- Connect the #5 SG terminal to remote equipment when the host (PLC) unit is not isolated. Connect the #5 SG terminal to a known reliable ground connection to reduce the risk of damaging the circuit.

Failure to follow these instructions will result in death or serious injury.

#### Serial Interface COM1

GP-4601T / GP-4603T: D-Sub 9 pin plug connector via an RS-232C cable.

Pin Connection		Pin No.	RS-232C			
			Signal Name	Direction	Meaning	
			1	CD	Input	Carrier Detect
			2	RD(RXD)	Input	Receive Data
5		9	3	SD(TXD)	Output	Send Data
			4	ER(DTR)	Output	Data Terminal Ready
		6	5	SG	-	Signal Ground
			6	DR(DSR)	Input	Data Set Ready
			7	RS(RTS)	Output	Request to Send
		J	8	CS(CTS)	Input	Send possible
(GP unit side)			9	CI(RI)/VCC	Input/-	Called Status Display
						+5V±5% Output 0.25A*1
			Shell	FG	_	Frame Ground (Common with SG)

NOTE: \*1 You can switch pin #9 between RI and VCC via software.

## **NOTICE**

#### **EQUIPMENT DAMAGE**

Use only the rated current.

Failure to follow these instructions can result in equipment damage.

Interfit bracket is #4-40 (UNC).

#### Recommendations:

- Cable Connector: XM2D-0901 manufactured by OMRON Corporation.
- Cable Cover: XM2S-0913 manufactured by OMRON Corporation.
- Jack Screw (#4-40 UNC): XM2Z-0073 manufactured by OMRON Corporation.

# **A** CAUTION

#### LOSS OF COMMUNICATION

- All connections to the communication ports must not put excessive stress on the ports.
- Securely attach communication cables to the panel wall or cabinet.
- Use only D-Sub 9 pin cables with a locking tab in good condition.

Failure to follow these instructions can result in injury or equipment damage.